

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J		PAGE OF PAGES 1 3		
2. AMENDMENT/MODIFICATION NO. 0002		3. EFFECTIVE DATE 23-Jun-2006		4. REQUISITION/PURCHASE REQ. NO. DPWRMB6129N929		5. PROJECT NO.(If applicable)	
6. ISSUED BY FORT BRAGG DIRECTORATE OF CONTRACTING ATTN: SFCA-SR-BR BUILDING 3-1632 BUTNER ROAD FORT BRAGG NC 28310-5000		CODE W91247		7. ADMINISTERED BY (If other than item 6) .CPT MICHAEL SPAHR MICHAEL.SPAHR@US.ARMY.MIL BLDG 1-1333 FORT BRAGG NC 28310		CODE W91247	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. W91247-06-T-0136	
				X		9B. DATED (SEE ITEM 11) 15-Jun-2006	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The reason for this amendment is to add additional requirements to the statement of work as specified in bold type starting at paragraph 6.1 and shown in the summary of changes.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: EMAIL:			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)		23-Jun-2006	
EXCEPTION TO SF 30 APPROVED BY OIRM 11-84				30-105-04		STANDARD FORM 30 (Rev. 10-83) Prescribed by GSA FAR (48 CFR) 53.243	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION A - SOLICITATION/CONTRACT FORM

The required response date/time has changed from 26-Jun-2006 04:00 PM to 28-Jun-2006 04:00 PM.

SECTION C - DESCRIPTIONS AND SPECIFICATIONS

The following have been modified:

STATEMENT OF WORK

SUBJECT: Project Number SF-00034-6P, Provide A/C in Server Room, SOTF, Building O-1900M, Fort Bragg, NC

GENERAL AND SPECIAL PROVISION

1. **General:** The contractor shall furnish all labor, materials, equipment, tools, supervision, transportation, and any other items necessary to upgrade electrical service. All work will be in strict compliance with these specifications, construction standards, building codes, and other contract documents.

2. **Location:** SOTF, Building O-1900M, Fort Bragg, NC

3. **Quality control:** The Contractor shall provide the job superintendent's name and telephone number to the Contracting Officer Technical Representative (COTR), **Mr. Fred Plummer at (910) 396-6682 (3) three days** prior to commencing work. Project Manager is Mr. Ninh Hoang at (910) 396-2787.

3.1. The Contractor shall accomplish all work skillfully and in accordance with good industry practices and IAW manufacturer's recommendations and specifications. All work shall conform to current codes and industry and construction standards.

4. **Hours of Work:** The Contractor shall accomplish all work between the hours of 7:30 a.m. and 4:00 p.m., Monday through Friday. No work will be done on weekends or Federal holidays without prior written approval from the Contracting Officer.

4.1. **Occupancy:** The building will be occupied during accomplishment of work. Interference with and inconvenience to the occupants or routine use of the facility shall be held to an absolute minimum. The Contractor is responsible for providing such coverings, shields, and barricades as required to protect the facility occupants, furniture, equipment, supplies, etc., from dust, debris, weather intrusion, or other damage resulting from construction.

4.2. **Clean up:** The Contractor shall remove all trash, debris or surplus materials from the work site at the end of each work day and shall leave the work site clean of all debris when work is completed. The Contractor shall coordinate with the COR in obtaining a PWBC dumping permit.

4.3. The Contractor shall not employ any person who is an employee of the U.S. Government if the employment of that person would create a conflict of interest.

4.4. Contractor's employees shall wear distinctive clothing bearing the company's name or wear a badge, which contains the company's name and the employee's name, clearly displayed at all times while working on Fort Bragg. The Contractor shall be responsible for the conduct and appearance of his/hers employees while working at Fort Bragg.

4.5. The Contractor is required to adhere to the safety requirements outlined in the Corps of Eng Manual EM 385-1-1.

4.6. Security, Safety, and Fire Protection: While working on Fort Bragg and other Government installations, you are required to comply with all Ft Bragg Security, Fire and Safety regulations/rules. You are also required to comply with all OSHA requirements. Safety equipment must be worn on all construction sites.

5. **Vehicle Registration:** The Contractor shall fully comply with the vehicle registration requirements regarding contractor-owned and contractor employee privately owned vehicles (POVs) as set forth in Fort Bragg Regulation 190-5. This regulation can be found at http://www.bragg.army.mil/16MP/vehicle_registration_information.htm. Any questions regarding this regulation can be directed to 910-432-8193. Please be advised that Contractor vehicles and contractor employee POVs will be searched if the appropriate passes/decals are not displayed when entering Fort Bragg Access Control Points (ACPs). All vehicles, including those with passes/decals, are subject to random search at any time.

6. Scope of Work: The Contractor shall furnish all labor, materials, equipment, transportation, tools, supervision and any other items necessary to: Provide one 40 ton water cooled computer room air conditioner. Provide one 1-ton fan coil unit in the office area. Extend the ductwork from the existing 5-ton unit to serve additional areas. Provide electrical wiring as shown on the drawing to provide complete and usable systems. All work shall be done in accordance with all state and local building codes and with DPW drawing #6641.

6.1. Demolish the return diffusers in the construction area. Provide new ceiling tiles in locations where the diffusers were removed. The new ceiling tiles shall match the existing tiles.

6.2. Provide a floor stand for the new computer room air conditioner

6.3 The fire damper on the new computer room air conditioner and on the existing computer room air conditioner shall be connected to the existing Fire Alarm Control Panel (FACP) located on the 2nd Floor in the control room.

6.4 Provide remote alarm for new HVAC in case the unit fails to operate. Remote alarm shall also be located in the 2nd Floor control room.

6.5 The existing piping to the Demolished VAV boxes shall be capped and abandoned in place.

6.6 The 150 Amp. Circuit breaker in Distribution Panel "B" is a new circuit breaker.

(End of Summary of Changes)